



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

550/3/26/L/IPSR

KEPADA :


- | | | |
|----------------|----------|---------|
| 1. Pak Khoirul | 3. Heri | 5. Anam |
| 2. Pak Syaiful | 4. Ricky | |

Selesai IPSRS

| TANGGAL LAPORAN | NOMOR LAPORAN | PELAKSANAAN | LOKASI |
|---------------------|---------------|---------------------|---------|
| 2026-03-02 10:40:21 | 3/3/26 | Senin, 2 Maret 2026 | Laundry |

| NAMA ALAT | MERK | MODEL | NOMOR SERI |
|---------------|------|-------|------------|
| Mesin Setrika | - | - | - |

| LAPORAN | TINDAKAN | KETERANGAN |
|----------------------------------|--|------------------|
| Mesin setrika error alarm safety | error safety, dikarenakan fuse pada relay safety putus | penggantian fuse |



SPAREPART

- | | |
|----|----|
| 1. | 4. |
| 2. | 5. |
| 3. | 6. |

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Heri

Ricky

Anam

Penerima Pekerjaan

Pak Henry

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG
Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016