



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

562/3/26/A/IPSRS

KEPADA :


1. Pak Khoirul
2. Pak Syaiful
3. Irawan
4. Heri
5. Ricky

Selesai Pihak Ke-3

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-02-19 08:53:43	153/2/26	Senin, 2 Maret 2026	Klinik Orthopedi VVIP
NAMA ALAT	MERK	MODEL	NOMOR SERI

AC

LAPORAN	TINDAKAN	KETERANGAN
AC/V2/10 (Poli Orthopedi VVIP) bocor	perbaiki unit ac	sudah tidak bocor



SPAREPART

- 1.
- 2.
- 3.
- 4.
- 5.
- 6.

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Irawan

Heri

Ricky

Penerima Pekerjaan

Bu Eka

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG
Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016