



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :


708/3/26/A/IPSR

KEPADA :

- | | | |
|----------------|-----------|----------|
| 1. Pak Khoirul | 3. Heri | 5. Ricky |
| 2. Pak Syaiful | 4. Irawan | 6. - |

Selesai Pihak Ke-3

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-03-16 08:58:02	163/3/26	Senin, 16 Maret 2026	IBS
NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	Array	Array	AC/B1/4
LAPORAN	TINDAKAN	KETERANGAN	
AC CENTRAL RUANG ADMIN SAMA RUANG RR PANAS	kabel outdoor lebas	AC kembali normal	



SPAREPART

- | | |
|----|----|
| 1. | 4. |
| 2. | 5. |
| 3. | 6. |

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Heri

Irawan

Ricky

Penerima Pekerjaan

Desi

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG
Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016