



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

829/4/26/A/IPSR

KEPADA :

- | | | |
|----------------|----------|-----------|
| 1. Pak Khoirul | 3. Anam | 5. Irawan |
| 2. Pak Syaiful | 4. Ricky | |

Selesai IPSRS

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-04-06 09:56:02	27/4/26	Rabu, 8 April 2026	Radiologi

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	Array	Array	AC/b/75

LAPORAN	TINDAKAN	KETERANGAN
AC/B/75 (Ruang operator CT Scan) bocor	pengecekan indoor dan normalisasi drainase	



SPAREPART

- | | |
|----|----|
| 1. | 4. |
| 2. | 5. |
| 3. | 6. |

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Anam

Ricky

Irawan

Penerima Pekerjaan

Era

Admin

Alivia Ayu Ninditya

bag. IPSRS RSUD SLG
Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016