



SURAT PERINTAH KERJA

INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

897/4/26/A/IPSRs

KEPADA :

- | | | |
|----------------|----------|------|
| 1. Pak Khoirul | 3. Anam | 5. - |
| 2. Pak Syaiful | 4. Ricky | 6. - |

Proses Pihak Ke-3

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-04-16 09:09:30	140/4/26	Kamis, 16 April 2026	PICU
NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	Array	Array	AC/b/49
LAPORAN	TINDAKAN	KETERANGAN	
AC/b/49 ampere kurang 2,7 dari 8,1	pengecekan indoor ampere kurang		



SPAREPART

-

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Anam

Ricky

Penerima Pekerjaan

Bu Silvi

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari
NIP. 198403012011012016