



# SURAT PERINTAH KERJA

## INSTALASI PEMELIHARAAN SARANA PRASARANA

NOMOR :

898/4/26/A/IPSR

KEPADA :

- |                |          |      |
|----------------|----------|------|
| 1. Pak Khoirul | 3. Anam  | 5. - |
| 2. Pak Syaiful | 4. Ricky | 6. - |

**Proses Pihak Ke-3**

TANGGAL LAPORAN	NOMOR LAPORAN	PELAKSANAAN	LOKASI
2026-04-16 09:10:06	141/4/26	Kamis, 16 April 2026	PICU

NAMA ALAT	MERK	MODEL	NOMOR SERI
AC	Array	Array	AC/b/48

LAPORAN	TINDAKAN	KETERANGAN
AC/b/48 ampere kurang 2,8 dari 3,84	pengecekan indoor ampere kurang	



**SPAREPART**

-

Mengetahui,

Teknisi Pelaksana

Pak Khoirul

Pak Syaiful

Anam

Ricky

Penerima Pekerjaan

Bu Slivi

bag. IPSRS RSUD SLG

Admin

Alivia Ayu Ninditya

Ka. IPSRS

Nova Dwi Hapsari  
NIP. 198403012011012016